



QUOTATION NOTICE


Sealed Quotations are hereby invited from reputed dealers and authorised license holders for supply and installation of Fire Safety/Fire fighting equipments in the school building of Baikhora English Medium H.S School, Baikhora, Santirbazar, South Tripura .

The Detailed guidelines & requisition(ADVISORY) issued by the Director of Fire & Emergency Services, Government of Tripura is available on the school website <https://bemhss.vidyajyotischools.co>

Sealed Quotation should be addressed to:
Assistant Headmaster, Head of Office & D.D.O, Baikhora English Medium H.S School, Baikhora, Santirbazar, South Tripura. PIN-799144.

Sealed Quotation may be submitted either in person or via Email at hmbkh16021301403@gmail.com / santikumarmolsom094@gmail.com

Submission of Quotation bid: w.e.f. 15/06/2026 to 22/06/2026
Date of Opening of quotation bid: 24/06/2026 at 1:00 P.M
For any Query please Contact:9862319806


Santi Kumar Molsom.
Asstt. Headmaster, Head of Office & D.D.O
Baikhora English Medium H.S School
South Tripura.

(SANTIKUMAR MOLSOM)
Assistant Headmaster
Head of Office & D.D.O.
Baikhora English Med. H.S. School
Baikhora, Santirbazar, Tripura(S)
D.D.O. Code : 22009



GOVERNMENT OF TRIPURA
DIRECTORATE OF FIRE & EMERGENCY
SERVICES
AGARTALA : TRIPURA



Phone: 0381-232-6451

Email: dg.fire-tr@gov.in

website:www.fireservice.tripura.gov.in

No: FSRTFES/2023/00081

Dated: 08/04/2026

To,
Joydip Nandi
Santirbazar, South Tripura
Baikhora B.O - 799144

Sub: **Fire Safety Recommendation** For Application Reference No **FSRTFES/2023/00081** .

With reference to your Application Reference No FSRTFES/2023/00081 Dated 16/02/2026 Fire Safety Recommendation on fire prevention and fire safety measures of the following building/premises is hereby issued in accordance with the conditions laid down in the relevant portions of Part-IV of the latest National Building Code and the Tripura Building Rules.

Name of the Applicant:	Joydip Nandi																																
Name of Owner with Plot details:	<table border="1"><thead><tr><th>S. No.</th><th colspan="3">Owner Name and Address</th></tr></thead><tbody><tr><td>1.</td><td colspan="3">ত্রিপুরা সরকারের পক্ষে শিক্ষা বিভাগ কর্তৃক রক্ষিত</td></tr></tbody></table>	S. No.	Owner Name and Address			1.	ত্রিপুরা সরকারের পক্ষে শিক্ষা বিভাগ কর্তৃক রক্ষিত																										
	S. No.	Owner Name and Address																															
	1.	ত্রিপুরা সরকারের পক্ষে শিক্ষা বিভাগ কর্তৃক রক্ষিত																															
	<table border="1"><thead><tr><th>S. No.</th><th>Plot No</th><th>Total Area</th><th>Classification</th></tr></thead><tbody><tr><td>1.</td><td>1864</td><td>0.35</td><td>টিলা</td></tr><tr><td>2.</td><td>1865</td><td>1.1</td><td>টিলা</td></tr><tr><td>3.</td><td>1866</td><td>0.22</td><td>টিলা</td></tr><tr><td>4.</td><td>306</td><td>5.6</td><td>টিলা</td></tr><tr><td>5.</td><td>307</td><td>1.42</td><td>টিলা</td></tr><tr><td>6.</td><td>308</td><td>0.63</td><td>নাল</td></tr><tr><td>7.</td><td>655</td><td>0.25</td><td>----</td></tr></tbody></table>	S. No.	Plot No	Total Area	Classification	1.	1864	0.35	টিলা	2.	1865	1.1	টিলা	3.	1866	0.22	টিলা	4.	306	5.6	টিলা	5.	307	1.42	টিলা	6.	308	0.63	নাল	7.	655	0.25	----
	S. No.	Plot No	Total Area	Classification																													
	1.	1864	0.35	টিলা																													
	2.	1865	1.1	টিলা																													
	3.	1866	0.22	টিলা																													
4.	306	5.6	টিলা																														
5.	307	1.42	টিলা																														
6.	308	0.63	নাল																														
7.	655	0.25	----																														
Name of the Property/ Organization/ Commercial establishment	Baikhora English Medium H.S. School																																
Address of the Building/ Premises:	Baikhora Habitation, East Charakbai Gram Panchayat, Jolaibari Block, Post Office Baikhora B.O - 799144, South Tripura District, Tripura.																																

A Fire Safety Certificate (FSC) will be issued, subject to verification of compliance of fire prevention and fire safety measures on which the fire safety recommendations enumerated in the attached letter and further submission of application through online system.

Director,
Fire & Emergency Services,
Or Authorized Signatory
Tripura : Agartala

***** WE SERVE TO SAVE*****

This certificate shall not be used by the Insurance service provider



Fire Safety Advisory and Suggestion:

- 1) ROAD WIDTH-10 METER,
- 2) GATE WIDTH-06 METER,
- 3) 02 NOS STAIRCASES TO UPPER FLOORS (EXIT),
- 4) WIDTH OF STAIRCASE UPPER FLOORS -1.5 METERS (EXIT),
- 5) NO. OF CONTINUOUS STAIRCASE TO TERRACE- 02 NOS (EXIT),
- 6) WIDTH OF CORRIDOR 1.5 METERS
- 7) 01 NO.CO2 FIRE EXTINGUISHER OF 4.5 KG CAPACITIES TO BE INSTALLED NEAR ELECTRIC MAIN PANEL BOARD. 01 NO. CO2 FIRE EXTINGUISHER HAVING CAPACITY OF 02 KG TO BE INSTALLED IN PRINCIPAL'S ROOM, EACH COMPUTER, LABS, HALL, AND SMART CLASS ROOMS OF THE SCHOOL BUILDING. 04 NOS CO2 EXTINGUISHER HAVING CAPACITY 02 KG TO BE INSTALLED AT A DISTANCE OF 15 M FLOOR WISE OF THE SCHOOL BUILDING
- 8) 04 NOS ABC TYPE FIRE EXTINGUISHER WITH 06 KG OF CAPACITY AT A DISTANCE OF 15 M TO BE INSTALLED EACH FLOOR WISE OF THE SCHOOL BUILDING. 01 NO. ABC FIRE EXTINGUISHER HAVING CAPACITY 06 KG TO BE INSTALLED IN EACH COMPUTER ROOM, STAFF ROOM, PRINCIPAL'S ROOM, LIBRARY AND OFFICE ROOM.
- 9) 04 NOS DRY CHEMICAL POWDER (DCP) TYPE FIRE EXTINGUISHER OF 06 KG CAPACITIES AT A DISTANCE OF 15 M TO BE INSTALLED EACH FLOOR WISE OF THE SCHOOL BUILDING.
- 10. 01 NO. STAND BUCKETS FILLED BY DRY SAND AND HANGING IN THE STAND TO BE INSTALLED IN THE SCHOOL ACADEMIC BUILDING AREA.
- 10. 01 NO. STAND BUCKETS FILLED BY DRY SAND AND HANGING IN THE STAND TO BE INSTALLED IN THE SCHOOL ACADEMIC BUILDING AREA.
- 12) HOSE REEL LENGTH 30 METERS
- 13) NOZZLE DIAMETER 19 MM
- 14) AN ALTERNATIVE SOURCE OF POWER IS REQUIRED
- 15) 04 NOS HOOTER'S WITH BATTERY BACKUP TO BE INSTALLED FLOOR-WISE
- 16) 02 NOS MANUAL CALL POINT WITH BATTERY BACKUP TO BE INSTALLED EACH FLOOR AND FIRE ALARM PANEL SHOULD BE INSTALLED.
- 17) DOWN COMER SYSTEM TO BE INSTALLED IN THE SCHOOL BUILDING WITH MILD STEEL PIPE MEASURING 100 MM/4" (INCH)/4.6 MM THICKNESS. 04 NOS. LANDING VALVE WITH A PRESSURE GAUGE INSTALLED AT EACH POINT IN EVERY FLOOR OF SCHOOL ACADEMIC BUILDING.
- 18) 01 NO TWO-WAY FIRE INLET TO BE INSTALLED IN FRONT SIDE AND 01 NO. IN BACK SIDE OF SCHOOL BUILDING,
- 19) 04 NOS OF DOUBLE DOOR HOSE BOX WITH 02 (TWO) NOS OF CANVAS RRL HOSE PIPES 15M & A SHORT BRANCH PIPE TO BE INSTALLED IN SPECIFIED POINT IN EVERY FLOOR OF ALL ACADEMIC BUILDING
- 20) TERRACE LEVEL PUMP DISCHARGE CAPACITY 450 LPM TO BE INSTALLED AT TERRACE LEVEL WITH A MINIMUM PRESSURE OF 3.5 KG/CM2
- 21) TERRACE LEVEL OF HEAD PUMP -50 METERS TO BE INSTALLED.
- 22) TERRACE LEVEL POWER SUPPLY SHOULD BE THREE PHASE
- 23) AUTO PUMP CONTROLLER SYSTEM TO BE INSTALLED IN THE TERRACE LEVEL PUMP ALONG WITH ON AIR RELEASE VALVE, PRESSURE GAUGE, AND PRESSURE SWITCH TO BE PROVIDE AT THE TERRACE LEVEL
- 23) AUTO PUMP CONTROLLER SYSTEM TO BE INSTALLED IN THE TERRACE LEVEL PUMP ALONG WITH ON AIR RELEASE VALVE, PRESSURE GAUGE, AND PRESSURE SWITCH TO BE PROVIDE AT THE TERRACE LEVEL
- 25) TERRACE TANK 10000 LITERS CAPACITY TO BE CONSTRUCTED IN THE BUILDING EXCLUSIVELY FOR FIRE FIGHTING PURPOSE
- 26) FIRE EXIT DOORS TO BE INSTALLED FROM GROUND FLOOR AND FIRST FLOOR WITH AND ALWAYS SHOULD BE KEPT FREE OF OBSTRUCTION FOR EASY EVACUATION IN CASE OF ANY EMERGENCY AND SIGN SHOULD BE CLEARLY VISIBLE.
- 27. A STANDBY POWER SUPPLY REQUIRED TO BE INSTALLED.
- 28) TRAINED PERSONS SHOULD BE APPOINTED TO OPERATE THE FIRE FIGHTING EQUIPMENT IN THE CASE OF ANY EMERGENCY
- 29)UNUSED COMBUSTABLE/INFLAMMABLE MATERIALS AND EXPLOSIVE SUBSTANCE SHOULD NOT BE STORAGE ANY WHERE IN THE SCHOOL ACADEMIC BUILDING. (30). FIRE EXTINGUISHER/ DOWN COMER/ HOSE REEL HOSE SHOULD NOT BE INSTALLED NEAR THE STAIRCASE. THE PROVISION OF PART (IV) OF THE LATEST NATIONAL BUILDING CODE 2016 OF INDIA (NBC) AND TRIPURA FIRE & EMERGENCY SERVICES ACT 2022.

Digitally signed by MEGHA JAIN
Date:13-04-2025 14:10:00 PM

