

Annexure- C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by

Er. Ranjit Debbarma (Assistant Engineer) (Name of Officers with designation)

from PWD (DWS), Sub-division, Jolaibari, Tripura (S) PHED

inspected the BAIKHORA ENG. MED. H.S. SCHOOL

(Name & Address of the school) on 28/07/2026 (date of inspection) and on the basis

of Water Test Report (Attached) bearing no. SL WTL/DWS/STB/26/613
dated 06/08/2026 of SDIB DIVISIONAL LEVEL WATER TESTING LAB (PHED Lab)

certified that the

BAIKHORA ENG. MED. H.S. SCHOOL (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains

the hygienic sanitation condition in the school building & the campus as per norms

prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 27/08/2027.

Signature with Seal:

Name

Designation

Name & Address of the Officer

To

Baikhora Eng. Med. H.S. School /
Santibazar, South Tripura
(Name & Address of the Institution)

28/08/2026
ER. RANJIT DEBBARMA
Assistant Engineer
PWD (DWS) Sub-Division
Jolaibari, Tripura (S).

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

GOVERNMENT OF TRIPURA
SUB-DIVISION LEVEL WATER TESTING LABORATORY
UNDER DWS SUB-DIVISION SANTIRBAZAR
SANTIRBAZAR, SOUTH TRIPURA, PIN-799144
PWD(DWS)



WATER TEST REPORT

Sample ID:- SLWTL/DWS/STB/26/613
Source/Location:- Baikhora English Medium H.S. School (A Vidyajyoti School)
Habitation/Ward:- -
GP/VC/MNC:- -
Block:- - Jolaibari
District:- South Tripura
State:- Tripura
Date of Collection:- 28-07-2026
Date of Received:- 06-08-2026
Date of Testing:- 06-08-2026
Sample Collector:-

Sl. No.	Parameter	Unit	Max. Requirement as per BIS 10500	Max Permissible Limit as per BIS 10500	Test Result	Remarks
1	Odor	NA	Agreeable	Agreeable	Agreeable	
2	Taste	NA	Agreeable	Agreeable	-	
3	Color	Hazen Units	5	15	02	
4	pH	NA	6.5-8.5	No relaxation	6.93	
5	Turbidity	NTU	1	5	0.41	
6	TDS	mg/l	500	2000	80	
7	Total Hardness	mg/l	200	600	54	
8	Alkalinity	mg/l	200	600	44	
9	Iron	mg/l	1	No relaxation	0.149	
10	Chloride	mg/l	250	1000	10	
11	Calcium	mg/l	75	200	-	
12	Magnesium	mg/l	30	100	-	
13	Free Residual Chlorine	mg/l	0.2	1	0	
14	Fecal Coliform	MPN/100ml	0	No relaxation	-	
15	Total Coliform	MPN/100ml	0	No relaxation	0	

Analysed by

(Chemist)

(Microbiologist)

Lab In-Charge

Sub-Division Level Water Testing Laboratory
PWD(DWS), Santirbazar, Tripura (S)

(This is the end of the Report)